

LEGEND

- ∅ Pipe Diameter
- Fire Hydrant
- Temporary Hydrant/End
- ⊗ Valve
- ① 11.25° BEND
- ② 22.5° BEND
- ③ 45° BEND
- ④ 90° BEND
- Ready Tap
- ◻ Water Meter
- Water Crossing
- Water Main
- DICL Water Main

NOTES

- Water main pipes are Ø150 PVC-0 Class PN16 unless noted otherwise.
- All road crossings are Ø150 DICL Class DN35 unless noted otherwise.



ENGINEER'S CERTIFICATION

I, MARK SHAW, being a certified / registered engineer and duly authorised representative of KN GROUP PTY LTD hereby

- Certify the information contained in the drawing is an accurate "AS CONSTRUCTED" representation of the works.

- Accept responsibility for the "AS CONSTRUCTED" information contained in this drawing.

- Acknowledge the "AS CONSTRUCTED" information contained in drawing may be relied on by Council and others.

Certification by _____ on _____

for KN GROUP PTY LTD
Registered Professional Engineer of Queensland - No. 17544

SURVEYOR'S CERTIFICATION

We T.H. JENSEN BOWERS PTY LTD, hereby certify that the vertical and horizontal locations and dimensions shown on this plan are a true and correct record and were located by survey.

T.H. Jensen
Director Date: 9/07/2021

AS CONSTRUCTED

A1

INDEX	DATE	REVISIONS	EC/JB	SJM	DB	PASSED	INITIALS	DATE
A	9/07/2021	Original Issue						

JENSEN BOWERS

SURVEYORS PLANNERS DEVELOPMENT ADVISORS

72 Coath Street, Fortitude Valley, Qld. 4006
PO Box 798, Spring Hill, Qld. 4004
T (07) 3852 1771 F (07) 3252 0818

T.H. Jensen & Bowers Pty Ltd (Consulting Surveyors)
Abn 52 614 872 807
© Copyright reserved to Jensen Bowers Group Consultancy Pty Ltd



Unitywater

9/07/2021

NORTHEAST BUSINESS PARK C/ - KN GROUP PTY LTD CONSULTING ENGINEERS
NORTH HARBOUR - STAGE 27
AS CONSTRUCTED WATER RETICULATION

SHEET 1 OF 1 SHEETS	SCALE 1:500
REVISION DATE 09/07/2021	REVISION A
DISCIPLINE CODE	
DRAWING NO. U-2020-1130	